



## ADDRESSABLE MANUAL CALL POINT TYPE : FD7150



**FD7150** Manual Call Point – It is designated to release a signal for a Fire condition to the Fire Control Panel IFS7002 upon manual activation by breaking the glass on the place, signed with arrows. The light indication for activating the manual call point is provided by a red LED. There is possibility for testing by a special key. It satisfies the requirements if the European Standard EN54-11 for a type A manual call point and EN54-17.

### TECHNICAL DATA

<b>System</b>	: Addressable
<b>Supply voltage</b>	: 15-30VDC
<b>Current in quiescent state</b>	: <290 $\mu$ A
<b>Current in alarm state</b>	: (3 $\pm$ 1)mA
<b>Degree of protection</b>	: IP 40
<b>Operating temperature range</b>	: -10°C to +55°C
<b>Relative humidity resistance</b>	: (93 $\pm$ 3)% at 40°C
<b>Dimensions</b>	: 90mmX90mmX44mm
<b>Material</b>	: ABS
<b>Colour</b>	: red
<b>Certification</b>	: EN54-11:2001/A1:2005, EN54-17:2005/AC:2007
<b>Manufacturer</b>	: UNIPOS Ltd
<b>Origin</b>	: European Union